



Chickasha Public Schools 900 W. Choctaw Ave. Chickasha, OK 73018

Chickasha Public Schools Safety and Security Project

4/7/2023

Addendum #1.

Bid date is hereby changed to Thursday April 13th, 2023 at 1PM CST.

The following are the question and answers to the RFI submitted.

Item 1: All locations: Please confirm door locations that required the removable center mullion to be functional and will need an electrified crash bar in lieu of electronic strike.

Answer: On doors where there is a removable mullion, it is suggested that you provide a quick disconnect at the top of the mullion for the door strike due to the higher cost of the electrified crash bar. Electrified crash bars should be limited to the doors on the drawings.

Item 2: Lincoln Elementary – Multiple classrooms with call/emergency button only. Missing emergency display/speaker/clock.

Answer: Specifications state:

“Each classroom shall have the following:

1. Supervised Network Emergency display/talk-back speaker – must be supervised from the speaker to the POE Switch without additional modules. No analog speakers connected to an IP module will be acceptable.
2. Call-in/emergency buttons – monitored for call line failure and notify a designated console operator immediately.
3. Customizable Virtual call stations that reside on classroom PC's.
 - a. Must have ability to acknowledge classroom is locked down in an emergency.

Provide emergency display/speaker/clock in each classroom

Item 3: Due to incomplete floor plans

Clarify that the following rooms/areas require intercom equipment •

Room 301 emergency display/speaker/clock, call/emergency button

Room 304 emergency display/speaker/clock, call/emergency button

Room 305 emergency display/speaker/clock, call/emergency button

Room 307 emergency display/speaker/clock, call/emergency button

Room 308 emergency display/speaker/clock, call/emergency button

Library emergency display/speaker/clock, call/emergency button



Chickasha Public Schools 900 W. Choctaw Ave. Chickasha, OK 73018

Hallways 3 additional speaker

Answer: See answer to item #2. Provide emergency display/speaker clock, call/emergency button and Virtual call button for these rooms per specifications. Add 3 speakers to hallways.

Item 4: High School Multiple classrooms with call/emergency button only. Missing emergency display/speaker/clock.

Answer: See answer to Item #2. Provide emergency display/speaker/clock in these classrooms and virtual call button per specifications.

Item 5: Grand Ave Elementary – Multiple classrooms with call/emergency button only. Missing Emergency display/speaker/clock.

Answer: See Answer to Item 2. Provide emergency display/speaker/clock and virtual call button for these rooms per the specifications.

The following is additional requirements for this project.

As-builts shall be maintained during the project and given to the owner at the end of the project. Final payment will not be made until these have been accepted by owner. The as-built drawings will have the following minimum information:

1. Wire pathways
2. Device type (model number)
3. IP addresses or MAC addresses for each endpoint
4. Clear and concise drawings via PDF. Drawings with hand written notes or hand drawn lines will not be acceptable.

See next pages for updated bid sheet adding the Activity Center and the Adult Learning Center (Quality Academy).



Chickasha Public Schools 900 W. Choctaw Ave. Chickasha, OK 73018

Bid Sheet

Administration Building Access Control: _____ Administration

Building Video Surveillance: _____ Administration Building

Emergency Notification: _____ High School Complex Access

Control: _____ High School Complex Video Surveillance:

_____ High School Visitor Management:

_____ High School Complex Emergency Notification:

_____ High School HALO Air Quality Sensors:

_____ Activity Center Access Control:

_____ Activity Center Video Surveillance:

_____ Activity Center Emergency Notification:

_____ Lincoln Elementary Access Control:

_____ Lincoln Elementary Video Surveillance:

_____ Lincoln Elementary Visitor Management:

_____ Lincoln Elementary Emergency Notification:

_____ Grand Elementary Access Control:

_____ Grand Elementary Video Surveillance:

_____ Grand Elementary Emergency Notification:

_____ Bill Wallace Access Control:

_____ Bill Wallace Video Surveillance:

_____ Bill Wallace Visitor Management:

_____ Bill Wallace Emergency Notification:

_____ Central Enrollment Access Control:

_____ Central Enrollment Video Surveillance:

_____ Central Enrollment Emergency Notification:

_____ Central Enrollment Emergency Notification:

_____ Central Enrollment Emergency Notification:



Chickasha Public Schools 900 W. Choctaw Ave. Chickasha, OK 73018

Adult Learning Center Access Control: _____ Adult Learning

Center Video Surveillance: _____ Adult Learning Center

Visitor Management: _____ Adult Learning Center Emergency

Notification: _____ Chickasha Middle School Access Control:

_____ Chickasha Middle School Video Surveillance:

_____ Chickasha Middle School Visitor Management:

_____ Chickasha Middle School Emergency Management:
